

ROOFTOP PYROTECHNICS PERMIT REQUIREMENTS

1. All safety rules specified in NFPA 1126 must be complied with.
2. All material shall be as specified by letter of intent, product list, and content of plan which has been approved by the Reno Fire Department.
3. No fallout will be allowed.
4. The roof must be wet down prior to the event.
5. One security person must be provided for each roof access point while pyrotechnics are in place.
6. No spectators shall be allowed on any rooftop unless authorized by the Reno Fire Department.
7. All combustible materials must be removed from the rooftop, with the exception of pyrotechnic racks.
8. Discharge areas shall have fire extinguishers as needed. Extinguishers shall have a current State of Nevada seal.
9. Contact Reno Fire Department Dispatch at 334-2306 prior to show.
10. The pyrotechnic operator shall provide a written record of all misfire pyrotechnics to the Reno Fire Department within 12 hours of the discharge.
11. The operator must hold a current State of Nevada Pyrotechnic Operator's License.
12. The Nevada Licensed Pyrotechnic Operator shall not leave the venue and/or discharge site until all pyrotechnic devices are rendered safe, including misfire locations after the discharge has taken place.
13. The discharge of pyrotechnics may be delayed or cancelled by the Reno Fire Department due to weather and/or safety conditions.
14. This permit shall be posted next to the launch site.

Additional requirements may be necessary based upon inspection and review of this event.